

凯威GFL系列钢结构接闪杆塔（避雷针）选用表

| 杆塔编 | 杆塔总高度 (m) | 修正后的地基承载力特征值 (KN/m ²) | | | 照明台 | | 杆塔总重 (kg) | 基础形式 |
|---------|----------------|---------------------------------------|-----|-----|-----|---|----------------|-------|
| | | 100 | 150 | 200 | 无 | 双 | | |
| GFL1-1 | 20 | √ | | | √ | | 1178.9 | JA-1 |
| GFL1-3 | 20 | | √ | | √ | | 1178.9 | JA-1 |
| GFL1-5 | 25 | √ | | | √ | | 1513.6 | JA-3 |
| GFL1-7 | 25 | | √ | | √ | | 1513.6 | JB-2 |
| GFL1-9 | 30 | | √ | | √ | | 1923.1 | JB-3 |
| GFL1-11 | 30 | | | √ | √ | | 1923.1 | JB-3 |
| GFL1-13 | 35 | | √ | | √ | | 2426.9 | JB-8 |
| GFL1-15 | 35 | | | √ | √ | | 2426.9 | JB-4 |
| GFL1-17 | 40 | | √ | | √ | | 3018.0 | JB-13 |
| GFL1-19 | 40 | | | √ | √ | | 3018.0 | JB-9 |
| GFL2-1 | 20 | √ | | | √ | | 1252.6 | JA-2 |
| GFL2-3 | 20 | | √ | | √ | | 1252.6 | JA-2 |
| GFL2-4 | 20 | | √ | | | √ | 1318.0 | JA-2 |
| GFL2-5 | 25 | √ | | | √ | | 1650.1 | JA-5 |
| GFL2-6 | 25 | √ | | | | √ | 1723.5 | JA-5 |
| GFL2-7 | 25 | | √ | | √ | | 1650.1 | JB-2 |
| GFL2-8 | 25 | | √ | | | √ | 1723.5 | JB-2 |
| GFL2-9 | 30 | | √ | | √ | | 2107.2 | JB-6 |
| GFL2-10 | 30 | | √ | | | √ | 2187.8 | JB-6 |
| GFL2-11 | 30 | | | √ | √ | | 2107.2 | JB-6 |
| GFL2-12 | 30 | | | √ | | √ | 2187.8 | JB-6 |
| GFL2-13 | 35 | | √ | | √ | | 2677.2 | JB-12 |
| GFL2-14 | 35 | | √ | | | √ | 2765.2 | JB-12 |
| GFL2-15 | 35 | | | √ | √ | | 2677.2 | JB-8 |
| GFL2-16 | 35 | | | √ | | √ | 2765.2 | JB-8 |
| GFL2-17 | 40 | | √ | | √ | | 3384.8 | JB-15 |
| GFL2-18 | 40 | | √ | | | √ | 3480.2 | JB-15 |
| GFL2-19 | 40 | | | √ | √ | | 3384.8 | JB-13 |
| GFL2-20 | 40 | | | √ | | √ | 3480.2 | JB-13 |